

# c-pro 3 micro+ and c-pro 3 kilo+ Programmable controllers

1 GETTING STARTED	
<b>1.1 Important</b>	Read these instructions carefully before installing and using the controller and follow additional information for installation and electronic connection. Keep these instructions close to the controller for future reference.
<b>1.2 INSTRUCTION</b>	<b>c-pro 3 micro+</b> and <b>c-pro 3 kilo+</b> are two families of programmable controllers. The families are available in the version:

• with 128 x 64 pixel single colour LCD graphic display (black with white segments) and 8 buttons (with preset functions) keyboard made of silicon rubber integrated in the controller, hereinafter also called built-in LCD versions (not available in **c-pro 3 micro+**)

• with 1 + 4 digit custom display (without function keys) and with a 6 buttons (with preset functions) keyboard made of silicone rubber integrated in the controller, hereinafter also called built-in LCD versions (**Graph**).

**Warning:** **Vroom** or **Vodoro** hereinafter also called blind versions. The controllers have got:

- real-time clock
- 9 analog inputs, of which 6 configurable via configuration parameter for PTC / NTC / Pt 1000 probes, 0-20 mA / 0-5 V or ambient / -0/10 V or 0-10 V
- 10 digital inputs and 3 configurable via configuration parameter for PTC / NTC / Pt 1000 probes, 0-20 mA / 0-5 V or ambient / -0/10 V or 0-10 V
- 9 non optoisolated digital inputs at 24 VAC / DC of which 7 at 50 / 60 Hz and 2 up to 2 kHz
- 6 non optoisolated analog outputs of which 2 configurable via configuration parameter for PWM / 0-10 V and 2 configurable via configuration parameter for 0-20 mA / 0-10 V signal and 2 for 0-10 V signal
- 4 digital outputs (electromechanical relays) of which seven res. A @ 250 VAC SPST and two 3 res. A @ 250 VAC SPDT outputs
- 4 non optoisolated analog outputs of which 2 configurable via configuration parameter for 0-20 mA / 0-10 V signal and 2 for 0-10 V signal
- 7 even 3 res. A @ 250 VAC SPST digital outputs (electromechanical relay) and an unipolar stepper electronic expansion valve driver
- 4 non optoisolated communication ports of which 1 LEB OTG port for programming and debugging, 1 CAN port with Modbus master communication protocol and 1 RS-485 port with Modbus slave communication protocol.

Through the **P** (expansion) **c-pro 3 micro+** or **c-pro 3 kilo+**, it is possible to increase the number of inputs and outputs. Through the development environment **NanoPro 3** (not separately) it is possible to realize the application software and through the connecting cable 08/05000/21 (2 m, 6.56 ft) or 08/05000/20 (1.64 ft long), to order separately, it is possible to program the controller. The device looks in case 2 DIN modules. Installation is in electrical panel on DIN rail. Through a common USB peripheral it is possible to make the upload and the download of the configuration parameters. For further information please consult the *Hardware manual of c-pro 3*.

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5 according to the model
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING
1	Digital outputs 6 and 7
2	Digital outputs 1...5
3	Digital output 9
4	Unipolar stepper electronic expansion valve driver
5	Digital input 7...9, digital inputs 6...9 and analog outputs 4...6
6	Analog inputs 1...6, digital inputs 1...5 and analog outputs 1...3
7	USB OTG port
8	Microswitch to display and keypad (not available in the blind versions)
9	RS-485 port with Modbus master communication protocol
10	RS-485 port with Modbus master communication protocol
11	Microswitch to plug in the termination of the RS-485 port with Modbus master communication protocol
12	Signaling LEDs
13	Digital output 8

The following table shows the meaning of the parts of the controller.

PART	MEANING




<tbl\_r cells="

**Working temperature:** from -10 to 60 °C (14 to 140 °F) for the built-in versions, from -20 to 60 °C (-4 to 140 °F) for the blind versions.

**Working humidity:** from 5 to 95% of relative humidity without condensate.

**Pollution situation:** 2

**Power supply:** 12 VAC, 50 / 60Hz, 7 VA max., supplied from a class 2 circuit in **c-pro** 3 micro, 24 VAC (+10 % - 15 %), 50 / 60 Hz, 10 VA max. or 20...30 DC, 5 W max., supplied from a class 2 circuit in **cpro 3 Kloc+**. Connect the power supply with a fuse rated 2aT-250V.

**Overvoltage category:** III

**Real time clock:** incorporated with a supercap battery

**Real time clock data maintenance in absence of power supply:** 3 days, will battery fully charged

**Analog inputs:** 9 analog inputs of which 6 configurable as configuration parameter for Pt/C/NTC/ Pt\_1000 probes, 0-20 mA/ 4-20 mA/ 0-5 V/Variometric, 0-10 V transducers and 3 configurable via configuration parameter for Pt/C/NTC / Pt\_1000 probes.

Power supply 0-5 V variometric transducers, 5 VDC / 60 mA max. Power supply 0-20 mA / 4-20 mA / 0-10V transducers, 12 VDC. The sum of the maximum current powered by the two power supply circuits is 120 mA.

**Working range:** from -50 to 150 °C (-58 to 302 °F) for Pt/C probe, from -50 to 120 °C (58 to 238 °F) for NTC probe, from -100 to 400 °C (-458 to 752 °F) for Pt\_1000 probe.

**Digital inputs:** 9 optoisolated digital inputs at 24 VAC / DC of which 7 at 50...60 Hz and 2 up to 2 kHz.

**Resolution:** 0.1 °C for Pt/C / NTC probes, 0.1 °C for Pt\_1000 probes, 0.01 mA for 0-20 mA / 4-20 mA transducers, 0.01 V for 0-10V transducers.

**Analog outputs:** 6 non isolated outputs

\* 2 outputs configurable via configuration parameter for PWM 0-10 V signal  
\* 2 outputs configurable via configuration parameter for 0-20 mA / 4-20 mA / 0-10 V signal  
\* 2 outputs for 0-10 V signal.

**Digital outputs:** according to the model:

- \* 9 outputs electromechanical relays of which seven 3 res. A @ 250 VAC SPST outputs (K1... K7) and two 3 res. A @ 250 VAC SPDT outputs (K8 and K9)
- \* 9 outputs of which seven 3 res. A @ 250 VAC SPST electromechanical relays (K1... K7) and two 24VAC/DC, 0.6 A max. solid state relays (K8 and K9)
- \* seven 3 res. A @ 250 VAC SPST outputs (electromechanical relays, K1... K7) and an unipolar stepper electronic expansion valves driver, 12 VDC, 260 mA max.

**Unipolar stepper electronic expansion valves driver:** 12 VDC, 260 mA max.

**Type of actions and additional features:** 18.

**Communication ports:** 4 non optisolated ports:

- \* 1 USB OTG port for programming and debugging
- \* 1 CAN port with CANbus communication protocol
- \* 2 RS-485 ports of which 1 with Modbus master communication protocol and 1 with Modbus slave communication protocol.

\* CPU: 120 MHz 168 MHz in the IoT version).

\* RAM: 192 kB (256 kB in the IoT version).

\* Program memory: 512 kB (1 MB in the IoT version).

\* External FLASH: 2 MB (2 MB in the IoT version).





Lo schema deve essere connesso alla massa solo in un punto.

• alimentazione isolata: 100 m (328 ft)

• uscita analogica di tipo PWM: 1 m (3.280 ft)

• uscita digitale: 100 m (328 ft)

• uscita digitale di tipo 0-20 mA/ 4-20 mA/V -0-10 V - 100 m (328 ft)

• uscite digitali (rete elettronemicani): 100 m (328 ft)

• uscita digitale (rete allo stato solido): 100 m (328 ft)

• altre per valvole di espansione elettromechaniche di tipo stepper unipolare:

3 m (9.842 ft)

3 m (9.845 ft); si veda anche il *Mannuale Modbus specification and implementation guide*

• porta CAN

1.000 m (3.280 ft) con baud rate 20.000 baud

• 500 m (1.640 ft) con baud rate 50.000 baud

- 250 m (820 ft) con baud rate 125.000 baud

- 30 m (98 ft) con baud rate 300.000 baud.

Si consiglia di utilizzare i kit di cablaggio CAV18 (monosette a vite estrattabili femmina passo 5,0 mm, Ø 196 in, da ordinare separatamente), il kit di cablaggio CAV19 (connettore Microfit femmina cablato, per **Cpro 3 micro**, da ordinare separatamente) e il kit di cablaggio CAV20 (monosette a vite estrattabili femmina passo 3,5 mm, Ø 137 in, per **Cpro 3 kic**, da ordinare separatamente).

Per programmare il controllo è consigliabile utilizzare il software *compsc* (versione 08.10500.018 (dilunghezza 2 m), 65,61 ft) o 08.10500.020 (dilunghezza 0,5 m), 1,640 ft), da ordinare separatamente.

**Temperatura di impiego:** da 10 a 60 °C (da 14 a 140 °F) per le versioni bullet, da 20 a 60 °C (da -4 a 40 °F) per le versioni cielle.

**Umidità di impiego:** dal 10 al 95% di umidità relativa senza condensazione.

**V**

**Categoria di sovratensione:** III

Orologio: incoppiato con batteria SuperCap®

**Mantenimento dati dell'orologio in assenza di alimentazione:**

res. 3 giorni con una batteria carica.

**Ingressi analogici:** 9 ingressi, di cui 6 configurabili via parametri di

configurazione per sonde PTC / NTC / Pt1000 (trasduttori 0-20 mA / 4-20 mA / 0-5 V / razionamento / 0-10 V e 3 configurabili via parametri di configurazione per sonde PTC / NTC / Pt1000.

Alimentazione/trasduttore razionario 0,5 V / 5 VDC, 60 mA max. Alimentazione/trasduttore 0,20 mA / 4-20 mA / 0-10 V / 12 VDC, 120 mA max.

La somma delle massime correnti fornibili dai due circuiti di alimentazione è di 120 mA.

**Campo di misura:** da -50 a 150 °C (da -58 a 302 °F) per sonde PTC, da -50 a 120 °C (da -38 a 48 °F) per sonde NTC, da -100 a 400 °C (da -148 a 752 °F) per sonde Pt1000.

**Ingressi digitali:** 9 ingressi opzionali a 24 VAC / DC di cui 2 fino a 2

KHz e 7 a 50 / 60 Hz.

**Risoluzione:** 0,1 °C per sonde PTC / NTC, 0,1 °C per sonde Pt1000.

Viaggio per i trasduttori 0-20 mA / 4-20 mA, 0,01 V per trasduttori

**Uscite analogiche:** 6 uscite non opzionali. Per ogni uscita è possibile utilizzare un parametro di configurazione per segnale di tipo PWM / 0-10 V

• 2 uscite configurabili via parametri di configurazione per segnale di tipo 0-20 mA / 4-20 mA / 0-10 V

• 2 uscite per segnale di tipo 0-10 V.

**Uscite digitali:** a seconda del modello:

• 9 uscite rette elettronemicani di cui 3 A res. @ 250 VAC di tipo SPST (K1, K7) e 2 da 3 A res. @ 250 VAC di tipo SPDT (K8 e K9)

• 9 uscite rette elettronemicani di cui 3 A res. @ 250 VAC di tipo SPST e 2 relé salvo solido da 24 VAC/DC, 0,5 A max. (K8 e K9)

• 2 uscite rette elettronemicane di 3 A res. @ 250 VAC di tipo SPST (K1, K7) e un driver per valvole di espansione elettroniche di tipo stepper unipolare.

**Driver per valvole di espansione elettroniche di tipo stepper unipolare:** 12 VDC, 260 mA max.

**Tipo di azioni e caratteristiche complementari:** I/B

**Porte di comunicazione:** 4 porti non opzionali:

• 1 porta USB OTG (per la programmazione e il debug)

• 1 porta CAN con protocollo di comunicazione CANbus e 1 con protocollo di comunicazione Modbus master e 1 con protocollo di comunicazione Modbus slave.

• CPU: 120 MHz / 168 MHz nelle versioni IoT

• RAM: 196 kB (512 kB) 1 MB nelle versioni IoT

• ROM esterna: 2 MB (2 MB nelle versioni IoT)